



www.castles-in-the-sky.co.uk

01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer

Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Kw/ Amps	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation $M\Omega$	Leakage mA	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
BLR1	Gibbons 0.75 Hp Ser.Fy124597	I	P	0.8	13	6+	12	☒	☒	☒	☒	0.07	>99.99	0.16	☒	☒	☒	☒
BLR2	AirQuee Blower 1.5 Hp.	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.03	>99.99	0.13	☒	☒	☒	☒
BLR3	Gibbons Blower, Ser.265419	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.04	>99.99	0.14	☒	☒	☒	☒
BLR5	AirQuee Blower 1.5 Hp.	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.05	>99.99	0.13	☒	☒	☒	☒
BLR6	Blower, Ser.SG11479C	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.03	>99.99	0.14	☒	☒	☒	☒
BLR7	Diamond-Fans.Com Blower, Ser.2015010005	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.04	>99.99	0.12	☒	☒	☒	☒
BLR8	Gibbon 1.5 Hp Ser.Fy128937	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.03	>99.99	0.14	☒	☒	☒	☒
BLR9	AirQuee Blower 1.5 Hp.	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.10	>99.99	0.13	☒	☒	☒	☒
BLR12	Gibbon 1.5 Hp Ser. TG 288004	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.04	>99.99	0.14	☒	☒	☒	☒

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Kw/ Amps	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒	Plug ☒	Flex ☒	Case ☒	Continuity Ω	Insulation $M\Omega$	Leakage mA	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
BLR13	Gibbons Blower, Ser.285776	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.04	>99.99	0.14	☒	☒	☒	☒
BLR14	AirQueue Blower 1.5 Hp.	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.01	>99.99	0.13	☒	☒	☒	☒
BLR15	AirQueue Blower 1.5 Hp.	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.04	>99.99	0.13	☒	☒	☒	☒
BLR16	AirQueue Blower, Ser.RH 24225c	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.09	>99.99	0.13	☒	☒	☒	☒
BLR17	Foshan Shunde Huawei 3 HP Air Blower, Ser.HW2017070 8990	I	P	3.2	13	6+	12	☒	☒	☒	☒	0.08	24.00	0.41	☒	☒	☒	☒
BLR19	Foshan Shunde Huawei 1.5 HP Air Blower, Ser.HW17072 29492	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.11	65.00	0.18	☒	☒	☒	☒
BLR20	Foshan Shunde Huawei 1.5 HP Air Blower, Ser.HW24413	I	P	1.1	13	6+	12	☒	☒	☒	☒	0.10	>99.99	0.19	☒	☒	☒	☒
BLR22	Foshan Shunde Huawei 1.5 HP Air Blower, Ser.HW201707 29571	I	P	1.5	13	6+	12	☒	☒	☒	☒	0.10	>99.99	0.18	☒	☒	☒	☒
BLR23	Foshan Shunde Huawei 3Hp. Air Blower, Ser.HW2021 39766	I	P	1.5	13	6+	13	☒	☒	☒	☒	0.09	52.45	0.20	☒	☒	☒	☒
BLR25	Foshan Shunde Huawei 1.5HP Air Blower, Ser.HW2022 40450	I	P	1.5	13	6+	13	☒	☒	☒	☒	0.15	>99.99	0.16	☒	☒	☒	☒

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Signature:

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
B4	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.02	>99.99	2.0	✓	✓	✓	✓
B10	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.04	>99.99	4.0	✓	✓	✓	✓
B11	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.01	>99.99	< 0.5	✓	✓	✓	✓
B12	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.02	>99.99	1.5	✓	✓	✓	✓
B14	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.02	>99.99	< 0.5	✓	✓	✓	✓
B44	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.02	>99.99	2.0	✓	✓	✓	✓
B6	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.08	>99.99	6.0	✓	✓	✓	✓
B30	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.07	>99.99	5.0	✓	✓	✓	✓
B49	30 Amp to 3 x16Amp. Adapter Unit	I	P	1.5	N/A	12+	12	✓	✓	✓	✓	0.01	>99.99	3 x 0.2	✓	✓	✓	✓
B29	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.03	>99.99	2.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
B16	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.02	>99.99	< 0.5	✓	✓	✓	✓
B17	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.10	>99.99	10.5	✓	✓	✓	✓
B19	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.10	>99.99	8.0	✓	✓	✓	✓
B21	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.08	>99.99	1.0	✓	✓	✓	✓
B26	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.05	>99.99	3.0	✓	✓	✓	✓
B27	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.06	>99.99	2.0	✓	✓	✓	✓
B28	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.01	>99.99	1.0	✓	✓	✓	✓
B1	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.62	>99.99	50.0	✓	✓	✓	✓
B3	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.36	>99.99	26.0	✓	✓	✓	✓
B13	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.06	>99.99	2.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer

Mike R Harris

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Signature:

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
B23	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.04	>99.99	2.0	✓	✓	✓	✓
B25	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.01	>99.99	< 0.5	✓	✓	✓	✓
B31	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.10	>99.99	8.5	✓	✓	✓	✓
B7	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.13	>99.99	10.0	✓	✓	✓	✓
B18	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.15	>99.99	9.0	✓	✓	✓	✓
B9	Extension Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.01	>99.99	< 0.5	✓	✓	✓	✓
B40	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.05	>99.99	4.0	✓	✓	✓	✓
B41	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.09	>99.99	8.0	✓	✓	✓	✓
B15	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.02	>99.99	2.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer

Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
B2	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.42	>99.99	35.0	✓	✓	✓	✓
B39	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	2.5	13	6+	12	✓	✓	✓	✓	0.37	>99.99	48.0	✓	✓	✓	✓
B8	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.38	>99.99	38.0	✓	✓	✓	✓
B37	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	2.5	13	6+	12	✓	✓	✓	✓	0.17	>99.99	23.0	✓	✓	✓	✓
B20	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.31	>99.99	25.0	✓	✓	✓	✓
B34	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.62	>99.99	50.0	✓	✓	✓	✓
B5	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.2	>99.99	17.0	✓	✓	✓	✓
B35	50.0 M Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.62	>99.99	17.0	✓	✓	✓	✓
B36	Extension Lead Fitted with 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.2	>99.99	18.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer

Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
B50	Internal 7 Mtrs. Extension Lead Within the Adult Castle	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.14	>99.99	7.0	✓	✓	✓	✓
B51	Internal 7 Mtrs. Extension Lead Within the 'Barbie' Castle	I	P	1.5	N/A	6+	12	✓	✓	✓	✓	0.15	>99.99	7.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
DOM2	Wickes 45M Reel Fitted with 2xDual BS 1363 Plug/Sockets	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.15	99.99	11.5	✓	✓	✓	✓
DOM3	Ext. Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.15	99.99	12.0	✓	✓	✓	✓
DOM5	Extension Lead Fitted with 2xDual BS 1363 Plug/Sockets	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.18	99.99	12.0	✓	✓	✓	✓
DOM7	Extension Lead Fitted with 2xDual BS 1363 Plug/Sockets	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.19	99.99	12.0	✓	✓	✓	✓
DOM9	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.10	99.99	8.0	✓	✓	✓	✓
DOM11	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.05	99.99	3.0	✓	✓	✓	✓
DOM12	Extension Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.11	99.99	7.0	✓	✓	✓	✓
DOM14	Ext. Lead Fitted with BS 1363 to 16 Amp BS EN 60309 Plug/Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.15	99.99	11.5	✓	✓	✓	✓
DOM10	Extension Lead Fitted with 2xDual BS 1363 Plug/Sockets	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.14	99.99	9.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse Amp.	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Cable Length Mtrs.	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
DOM15	Extension Lead Fitted with Dual BS 1363 Plug/Sockets	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.03	99.99	< 0.5	✓	✓	✓	✓
DOM18	Lead Fitted with BS 1363 Plug / 16amp Socket	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.15	99.99	18.5	✓	✓	✓	✓
DOM16	Lead Fitted with BS 1363 Plug / 16amp Socket	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.02	99.99	< 0.5	✓	✓	✓	✓
DOM21	Lead Fitted with BS 1363 Socket / 16amp Plug	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.08	99.99	1.0	✓	✓	✓	✓
DOM6	Extension Lead Fitted with BS 1363 Plug/Sockets	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.04	99.99	4.5	✓	✓	✓	✓
DOM4	Wickes Reel Fitted with 2xDual BS 1363 Plug/Sockets	I	P	1.25	13	6+	12	✓	✓	✓	✓	0.38	>99.99	25.0	✓	✓	✓	✓
DOM20	Power adapter for sound System	II	P	N/A	13	6+	12	✓	✓	✓	✓	N/A	99.99	0.10	✓	✓	✓	✓
DOM8	Wickes 4 way Extension Lead Fitted with BS 1363 Plug/Sockets	I	P	1.5	13	6+	12	✓	✓	✓	✓	0.14	99.99	9.0	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description					Frequency of Formal		Condition of...		Loop Impedance Test	Continuity				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Case ☒ ☒	Plug ☒ ☒	Zs	X1 Tripping I		X5 Tripping I		Function ☒ ☒	Envirmnt. ☒ ☒	Use & Test Pass ☒ ☒
											s0°	s180°	s0°	s180°			
RCD1	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	12.16	11.04	10.08	9.56	✓	✓	✓
RCD2	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.03	6.08	10.16	9.80	9.00	✓	✓	✓
RCD4	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	11.20	10.28	9.64	9.04	✓	✓	✓
RCD5	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	16.84	16.44	15.24	15.52	✓	✓	✓
RCD6	In Line Residual Current Device Lead 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	12.20	11.48	10.76	10.08	✓	✓	✓
RCD7	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.04	20.52	19.32	12.72	13.00	✓	✓	✓
RCD8	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	16.32	20.52	16.36	16.64	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599
Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer Mike R Harris

Signature:

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description					Frequency of Formal		Condition of...		Loop Impedance Test	Continuity				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Case ✓ ✗	Plug ✓ ✗		Zs	X1 Tripping I		X5 Tripping I		Function ✓ ✗	Envirmnt. ✓ ✗
										s0°		s180°	s0°	s180°			
RCD9	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	11.92	11.12	10.20	9.64	✓	✓	✓
RCD11	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.01	13.08	12.48	12.00	11.32	✓	✓	✓
RCD12	In Line Residual Current Device Lead 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	22.15	23.96	19.00	16.68	✓	✓	✓
RCD13	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	22.42	19.16	18,08	16.60	✓	✓	✓
RCD14	In Line Residual Current Device Lead 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.04	10.92	9.80	9.40	8.88	✓	✓	✓
RCD15	Residual Current Device 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.02	19.00	16.76	15.84	15.60	✓	✓	✓
RCD16	In Line Residual Current Device Lead 30 mA < 42Ms Tripping Time					6+	12	✓	✓	0.05	9.72	8.88	8.36	12.48	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire



www.castles-in-the-sky.co.uk

☎ 01452 559599

Mobile: 07814275079

Test Date:	14/02/2025
Inspect Only Inspect Plus Test	Inspect + Test

Test Engineer

Mike R Harris

Castles in the Sky
8 Diamond Jubilee Close
Gloucester
GL14LR

Signature:

.....

Equipment Formal Visual & Combined Inspection & Test Record

Equip. ID	Make * Model * Serial * Description	Class	Type	Cable C.S.A mm ²	Fuse	Frequency of Formal		Condition of.....				Test Results				Suitable for Environment / Function Continued Use + Test PASS		
						Visual Months	Visual +Test Months	Socket ☒ ☒	Plug ☒ ☒	Flex ☒ ☒	Case ☒ ☒	Continuity Ω	Insulation MΩ	Leakage mA	Polarity ☒ ☒	Function ☒ ☒	Envirmnt. ☒ ☒	Cont. Use & Test Pass ☒ ☒
PB27	Air Heater Mod. HT-1E 2500W S/N HW 2017071 9166	I	P	1.5	13	12+	12	✓	✓	✓	✓	0.03	>99.99	0.10	✓	✓	✓	✓
PB28	Air Heater Mod. HT-1E 2500W S/N HW 2017071 9167	I	P	1.5	13	12+	12	✓	✓	✓	✓	0.02	>99.99	0.10	✓	✓	✓	✓
PB29	beamZ Magic Jelly Ball RGB LED 3x3WDisco Light	II	P	0.5 x2	3	12+	12	✓	✓	✓	✓	N/A	>99.99	0.10	✓	✓	✓	✓
PB30	2 Mtr. Supply Cable BS 1363 Socket to IEC Connector	I	P	1.00	5	12+	12	✓	✓	✓	✓	0.04	>99.99	N/A	✓	✓	✓	✓
PB31	Vonyx SPJ 1200ABT Active Speaker	I	P	N/A	N/A	12+	12	✓	✓	✓	✓	0.10	>99.99	0.10	✓	✓	✓	✓
PB32	www.tronios.com 153.219 Disco Ball Light	II	P	0.75 2x	3	12+	12	✓	✓	✓	✓	N/A	>99.99	0.10	✓	✓	✓	✓
PB33	2 Mtr. Supply Cable BS 1363 Socket to IEC Connector for PB36	I	P	0.75	5	12+	12	✓	✓	✓	✓	0.06	>99.99	N/A	✓	✓	✓	✓
PB36	MAK 650W Portable P.A. Amp. PA-PORT12ECO	II	P	N/A	N/A	12+	12	✓	✓	✓	✓	N/A	>99.99	0.10	✓	✓	✓	✓

Note... (✓) Indicates PASS, (✗) indicates FAIL --- (N/A) Not Applicable --- (N/C) Not Checked/Tested --- (*) Denotes if Applicable --- (+) Operator Check @ Each Hire